
PHONE (505) 397-4414 • P.O. BOX 5013 • HOBBS, NEW MEXICO 88241

HYDROSTATIC PRESSURE TEST OF B.O.P. EQUIPMENT SANTA FE ENERGY STATE FEDERAL # 1

> TMBR/SHARP DRILLING RIG # 27 FIELD TICKET # 1496

> > 10-19-89

CC BUREAU OF LAND MANAGEMENT



## ARRIVED LOCATION RIG NIPPLING UP

TEST # 1 Test blind rams and valves 1,2,3,6
Fressure to 3000 PSI
Five minute test
Grease zert on valve 4 leaks

TEST # 2 Retest blind rams and valves 1.2,3,6
Pressure to 3000 PSI
Five minute test
No visible leak

TEST # 3 Test pipe rams and valves 4 & 5
Pressure to 3000 PSI
Five minute test
No visible leak

TEST # 4 Test valve 7
Pressure to 3000 PSI
Five minute test
No visible leak

TEST # 5 Test Hydril
Pressure to 1000 PSI
Five minute test
Flange on bottom of hydril leaks

TEST # 6 Retest Hydril Leaks by hydril

TEST # 7 Retest Hydril
Hydril will not test

TEST # 8 Test dart valve
Pressure to 2000 PSI
Five minute test
No visible leak

TEST # 9 Retest dart valve
Pressure to 3000 PSI
Five minute test
No visible leak

TEST # 10 Test upper kelly valve
Pressure to 3000 PSI
Five minute test
Leaks between lower kelly valve and kelly


## DETAILS OF B.O.P. TEST CON'T


TEST	#	1.1	Retest upper kelly valve
			Pressure to 3000 PSI
			Five minute test
			No visible leak


TEST	#	12	Test	lower	kelly	valve
			Pres	sure t	a 3000 a	PSI
			Five	minut	e test	
			No v	isible	leak	

TEST	#	13	est Hydril	
			ressure to 1000	PSI
			ive minute test	
			o visible leak	

TESTING COMPLETED BY WAYNE MASSIE









## **SAFETY TEST**Safety Test of Texas

P.O. Box 5013 Hobbs, N.M. 86241 Hobbs (505) 397-4414 Odessa (915) 333-6393

DATE 10/19/89 CONTRACTOR TIMORE	Shace RIG NO. 2>
COMPANY SANTE FE EWERGY WELL NAME	STATE FED. Am #1
L.S.DFIELD/AREA	
Test was made with 10 00 and (plug) (packet	r) or both
Arrived location and rig was (doing what)	up
What changes (if any) were made to BOP hook-up since previous test	
None	
Closing System:	
List any delay observed to operation of BOP's during test; and	I, loss of closing pressure (other than Hydril
test) NON E	-
2. List items replaced during testing ///DF//	
3. Closures were made using pump accumulators	_ for test to Hydril.
5. Control valves operated as indicated on closing unit manifold exce	ept: WOW
6. Extensions were () or were not () hooked up  No test desired to	
Items leaking at the conclusion of testing and/or malfunction of BOP'	
Wove	
	<u></u>
Company representative am Brown	Phone
Rig Supervisor	<b>DI</b>

NOV 2 1989
HOUSE CHACE