

ITEM	DESCRIPTION	A. B. CHANGE NO.	JOSLYN NO.	OTHER MFRS. NO.	NO SUB.
1	Private circuit - 100 amp, 15 KV, 16000 amp int. cap.	F2XX1015G			X
2	General purpose "up" bolt clamp	UC510AGP			
3	11 kv. 100 amp. arresor, 10 KV				
4	single phase oil switch, 14.4 KV			HEGAK-10100N AMC2	
5	split bolt connector, size req'd			BLACKHORN "F" SERIES	
6	grounding spec. see dwg. No. ES-11 & ES-1A, Note 3				
7	35' class 4 crossoset pine pole				
8	Aluminum deadend preforms for ACSR, size req'd				
9	30' class 6 crossoset pine pole				
10	60' class 6 crossoset pine pole				
11	ES-1A - Note 3				
12	ground connector, motor			BULKWY KC-22	X
13	600 V. secondary lightning arresor single phase				
14	Greenfield type "F" liquid-tight flexible steel conduit, size req'd, w/ necessary liquid-tight connectors.				
15	req'd size 1/8 fitting & cover & basket				
16	transformer tank grounding terminal	GW5-15			
17	Hird Guards (insulating boots on transformer bushings)			UC510AGP	

DATE: 12-27-71		TITLE: DESCRIPTION MATERIAL	
DRAWN BY: E. WINTER		CCNOCO HOBBS DIVISION	
DESIGN BY:			
CHECKED BY:			
APPROVED BY:		PRODUCTION DEPT.	JOB: FLEC SPECS
SCALE: NONE		DRAWING NO: ES-1	
		SHEET 2 OF 3	