

ITEM	DESCRIPTION	A. B. CHANGE NO.	JOSLYN NO.	OTHER PERS. NO.	NO SUB.
AA	Primary circuit - 100 AMP, 15 KV, 16000 amp. inc. cap.				
BB	General purpose 100 amp bolt clamp	12-10-56			X
CC	Lightening arrester, 10 KV	12-10-56			
DD	Single phase oil switch, 10 KV				
EE	Split bolt connector, wire req'd				
FF	Grounding spade, see spec. for 15-11 & 15-12, Note 3				
GG	35' class 4 creosoted pine pole				
HH	Aluminum deadend bracket for ACSR, also req'd				
II	30' class 6 creosoted pine pole				
JJ	60' class 6 creosoted pine pole				
KK	60' class 6 creosoted pine pole				
LL	Ground connector, motor				
MM	20' class 6 creosoted pine pole				
NN	Greenfield type 15 liquid-tight flexible steel conduit, also req'd, w/ necessary liquid-tight connections				
OO	10' class 6 creosoted pine pole				
PP	Transformer tank mounting terminal				
QQ	10' class 6 creosoted pine pole				

DATE: 12-27-71	TITLE: DESCRIPTION MATERIAL
DRAWN BY: E. MANIAX	CONOCO
DESIGN BY:	
CHECKED BY:	
APPROVED BY:	
SCALE: NONE	PRODUCTION DEPT: HOBBS JOB: ALEC SPECS DRAWING NO: ES-1 SHEET: 3