

ITEM	DESCRIPTION	A. B. CHANGE NO.	JOSLYN NO.	OTHER MFRS. NO.	NO SUB.
AA	Primary Cutout - 100 amp, 15 KV, 16000 amp int. cap.	EXX10/5G			X
AB	General Purpose high bolt clamp	UC510AGP			
AC	Lightening arrester, 10 KV				
AD	Single phase oil switch, 15.4 KV				
AE	split bolt connector, size req'd				
AF	Grounding specs. see det. No. ES-11 & ES-1A, Note 3				
AG	35' class 4 crossroed pine pole				
AH	Aluminum deadend Preforma for ACSR, size req'd				
AI	30' class 6 crossroed pine pole				
AJ	OVERHEAD GRND, 94 ACSR - 16 Req'd - Ref. Det. ES-11,				
AK	ES-1A - Note 3				
AL	Ground connector, motor				
AM	600 V. secondary lightning arrester, single phase				
NN	Greenfield Type EF liquid-tight flexible steel conduit, size req'd, w/ necessary liquid-tight connectors.				
OO	req'd size 1/2 fitting & cover & gasket				
PP	transformer tank grounding terminal				
QQ	Bld Guards (insulating boots on transformer bushings)	GW5-75			

DATE: 12-27-71		TITLE: DESCRIPTION MATERIAL	
DRAWN BY: E. WINTER		CONOCO HOBBS DIVISION DRAWING NO. 1 SHEET 2 OF 3	
DESIGN BY:			
CHECKED BY:			
APPROVED BY:			
SCALE: NONE		REC. SPECS	