

CONTINENTAL OIL COMPANY
VAUGHN A-12 NO. 2 Power Distribution

A plat is attached showing the proposed well location, existing road, new road, existing power line, proposed power line, also drawings of the pole design.

It is proposed to tie in to an existing New Mexico Electric primary line and construct 2 spans (660') of primary line. The poles will be approximately 330' apart, 1-line pole and 1 pole with transformer bank. a 20' Right-of-Way will be required to install this line. The proposed line is sketched.