

ITEM	DESCRIPTION	A. B. CHANCE NO.	JOSLYN NO.	OTHER MFRS. NO.	NO. SUB.
a	double unset bolt s/sq. nut, round washer, and cotter key on short end, sq. nut and HP locknut on long end, 15 1/8" long (or length required.)	7828			
b	wet process porcelain secondary spool insulator, 3" brown glaze		1101		
d	required size conduit w/ servicehead(s) & req'd size & rated insulated conductors. Ref. DWG ES-1B Note: provide clamp and ground conduit parallel groove clamp, size req'd			FOR NBY SERIES "UC"	
e	parallel groove clamp, size req'd				
f	secondary insulator clevis for 4" insulator	6510			
g	5/8" thimbleye nut				
h	5/8" x 12" (or length req'd) straight thimbleye bolt w/sq. nut	5512		ALUMA-FORM 6M3-6	X
j	transformer cluster mount bracket (small)			ALUMA-FORM 15M3-6	X
l	transformer cluster mount bracket (large)				
m	req'd size raintight disconnect & fuses, 3-phase, 600 V. Ref. DWG No. ES-1B				
n	16" cross plate anchor (or size req'd)	X-16 88135			
q	8-way expanding anchor (size req'd)		10101		
t	4" brown glaze wet process porcelain secondary spool insulator				
u	5/8" x 7' thimbleye anchor rod w/nut (use twineye if req'd - Chance No. 5347)	5317 (NUT 55006P)			
aa	3/8" high strength guy strand (10,800 lb.)				
bb	preformed guy grip for 3/8" guy strand	5010			X
dd	5/8" x 10" angle thimbleye bolt w/nut	6A-3 1/2			
ee	3"x3"x1/4"x11/16" hole curved washer				
ff	6" - guy clamp w/3-1/2" bolts	6454			
gg	medium size strain insulator				X
hh	serving sleeve for 3/8" guy strand	7887			
jj	3/16" x 2-1/2" x 7" lift plate				
nn	pole bottom ground plate (may use butt-wrap if desired)				
qq	Ground Connection (See DWG. ES-12)				
rr	wet process porcelain secondary spool insulator, 3" - white glaze				
tt	wet process porcelain secondary spool insulator, 4" - white glaze				

DATE: 12-27-71

DRAWN BY: E. WINTER

DESIGN BY:

CHECKED BY:

APPROVED BY:

SCALE: NONE

TITLE:

DESCRIPTION MATERIALS

CONOCO

PRODUCTION DEPT.

JOB:

ELEC SPECS

DRAWING NO.:

ES-1

SHEET 3 OF 3

HOBBS DIVISION