



ITEM	QTY	REF
B	4	
C	9	
D	2	
E	3	
F	24	
G	12	
H	8	
J	8	
K	8	
L	8	
Prod	1	ES14, NOTE 5
5	6	
7	3	
U	3	
W	5	
X	1	
Y	3	
Z	3	
AD	3	
CG	3	
EE	8	
FE	1	
HN	6	
P	1	
JL	1	ES14, NOTE 2
MM	1	
FF	3	
QA	6	

1. CENTER PHASE ON PAIR WILL HAVE EPOXY INSULATOR, KEENESEY # 223015-24 INS. (REF. - REFER TO DRAW. E-25)

2. ALL WIRE FROM POINT "U" WILL BE INSULATED TYPE WIRE ON TRANSFORMER PAIR.

DATE:	12-11-79	TITLE:	SINGLE POLE SCOBSTA.
DRAWN BY:	AKO		1 PM. TRANS. CLUSTER MOUNT
DESIGN BY:	AKO		PRIM DEAD-END. 11350/480 V ACGR
CHECKED BY:		PRODUCTION DEPT.	
APPROVED BY:		JOB:	
SCALE:	NONE		ELIC SHEETS
		CONOCO HOBBS DIVISION DRAWING NO.: ES-9	