

# PLANS PETROLEUM OPER. CO.

Operator: PPOC	Well Name: E C HILL B FED #12
Project ID:	Location: 985' FSL 550' FEL

## Design Parameters:

Mud Weight (10.20 ppg) : 0.530 psi/ft  
 Shut in casing pressure : 1565 psi  
 Internal gradient (burst) : 0.008 psi/ft  
 Annular gradient (burst) : 0.530 psi/ft  
 Tensile load is determined using buoyed weight  
 Service rating is "Sweet"

## Design Factors:

Collapse : 1.125  
 Burst : 1.10  
 8 Round : 1.75 (J)  
 Buttress : 1.60 (J)  
 Other : 1.50 (J)  
 Body Yield : 1.50 (B)

	Length (feet)	Size (in.)	Weight (lb/ft)	Grade	Joint	Depth (feet)	Drift (in.)	Cost
1	100	8.625	32.00	K-55	ST&C	100	7.875	
2	2,100	8.625	24.00	K-55	ST&C	2,200	7.972	
3	800	8.625	32.00	K-55	ST&C	3,000	7.875	

  

	Collapse Load (psi)	Strgth (psi)	S.F.	Burst Load (psi)	Min Int Strgth (psi)	Yield S.F.	Tension Load (kips)	Strgth (kips)	S.F.
1	53	2427	9.999	1565	3930	2.51	66.85	402	6.01 J
2	1166	1348	1.156	1513	2950	1.95	64.15	263	4.10 J
3	1590	2530	1.592	417	3930	9.41	21.61	402	18.61 J

Prepared by : DJB, Midland, Texas

Date : 09-19-1994

Remarks :

LEA COUNTY, NEW MEXICO

Minimum segment length for the 3,000 foot well is 100 feet.

SICP is based on the ideal gas law, a gas gravity of 0.15, and a mean gas temperature of 89°F (Surface 74°F , BHT 104°F & temp. gradient 1.000°/100 ft.)

Surface/Intermediate string:

Next string will set at 3,000 ft. with 8.80 ppg mud (pore pressure of 1,371 psi.) The frac gradient of 0.700 at the casing seat results in an injection pressure of 2,100 psi. Effective BHP (for burst) is 1,590 psi, the BHP load is 0 psi (using an annular mud of 10.00 ppg) and the differential gradient is -0.520 psi/ft.

The minimum specified drift diameter is 7.875 in.

NOTE: The design factors used in this casing string design are as shown above. As a general guideline, Lone Star Steel recommends using minimum design factors of 1.125 - Collapse (with evacuated casing), 1.0 - Burst, 1.8 - 8 Round Tension, 1.6 - Buttress Tension, and 1.5 - Body Yield. Collapse strength under axial tension was calculated based on the Westcott, Dunlop and Kenler curve. Engineering responsibility for use of this design will be that of the purchaser. Costs for this design are based on a 1987 pricing model. (Version 1.06)