

ITEM	DESCRIPTION	A. B. CHANCE NO.	JOSLYN NO.	OTHER MFGS. NO.	NO. SUB.
A	35' class 6 creosoted pine pole				
B	3 1/2" x 4 1/2" x 8' creosoted crossarm				
C	High density wet process porcelain pin insulator		463		
D	3/8" x 3/4" forged steel pin w/eq. washer, nut, & locknut	881			
E	3/8" x 17" machine bolt w/ nut (or length req'd)	881/2			
F	2 1/4" x 2 1/4" x 3/16" x 11/16" hole eq. washer	681/3			
G	3/8" MF Locknut	351/2			
H	1/4" x 1 1/4" x 28" flat crossarm brace	712/8			
J	1/2" x 6" E2 Pattern Drive Log Screw	308754			
K	3/8" x 4 1/2" Carriage Bolt w/ Nut	86341/2			
L	3/8" MF Locknut	351/0			
M	Preformed Aluminum Alloy Armor Rods, size req'd				
N	ele. wire 66 strong alum. alloy				
O					
P	33' class 5 creosoted pine pole				
R	Aluminum double end Squeeze on Connector for AGSR, Aluminum, or Copper-also req'd			KEARNEY SERIES "B1"	X
S	6" Suspension Insulator	66400			
T	5/8" Standard Oval Eye Nut	6502			
U	Primary Dead End Clamp		44050		
V	5/8" x 18" (or length req'd) Double Arming Bolt w/4 eq. nuts	8868			
X	guying detail - see det. No. ES-10 for specs.				
Y	Hot Line Clamp				
Z	Squeeze on bracket, also required	5152046P		KEARNEY	X

DATE: 12-27-71	TITLE: DESCRIPTION MATERIALS	
DRAWN BY: E. WINTER		
DESIGN BY:		
CHECKED BY:		
APPROVED BY:		
SCALE: NONE		
PRODUCTION DEPT. CONOCO		HOBBS DIVISION DRAWING NO. ES-1 SHEET 1 OF 3
JOB: ELEC SPECS		

46115 B1 NO.4

RECEIVED

MAY 3, 1977

CLINTON COUNTY COMM.
HOBBS, E. M.