

ITEM	DESCRIPTION	A. B. CHANGE NO.	JOSLYN NO.	OTHER MFRS. NO.	NO SUB.
AA	Primary Cutout - 100 amp, 15 KV, 16000 amp int. cap.	F2XX1015G			X
BB	General Purpose "00" bolt clamp	UC310AGP			
CC	Lightening arrester, 10 KV				
DD	Single phase oil switch, 14.4 KV			HYBAM-EDISON RMWC2	
EE	split bolt connector, also req'd			BLACKBURN W 51615	
FF	Grounding specs. see dwg No. ES-11 & ES-1A, Note 3				
GG	35' class 4 creosoted pine pole				
HH	Aluminum deadend preforms for ACSR, also req'd				
IJ	30' class 6 creosoted pine pole				
KK	OVERHEAD GRND, 4x ACSR - If Req'd - Ref. Dwg ES-11, ES-1A - Note 3				
LL	Ground connector, motor				
MM	600 V. secondary lightning arrester single phase			BLACKBURN KC-22	X
NN	Greenfield Type EF liquid-tight flexible steel conduit, also req'd, w/ necessary liquid-tight connectors;				
OO	req'd also for fitting & cover & gasket				
PP	transformer tank grounding terminal	GW3-15			

DATE: 12-27-71		TITLE:	
DRAWN BY: E. WINTER		DESCRIPTION MATERIAL	
DESIGN BY:			
CHECKED BY:			
APPROVED BY:			
SCALE: NONE			
PRODUCTION DEPT.		DRAWING NO:	
JOB:		HOBBS DIVISION	
REC SPECS		ES-1	
		SHEET 2 OF 3	

W115 B-1 NO. 4

RECEIVED

MAY 10 1977

OIL CONSERVATION COMM.
ROBBS, N. H.