

BENHAM NATURAL GAS SERVICE, INC.

Phone: 915/377-9222 2317. Field St. - Unit J Odessa Texas 79761

PHYSICAL TEST AND METER REPORT

Test Date 5-10-99		Effective Date 6-99		Plant JAL	
Operator Lantexco			Purchaser SRGC		
Lease EL Palo Ruby Feeds #1					
Meter Station No. 58268	Conn. (✓) Flange () P.T.	Conn. Line Size 4.0 3 10	Orifice .51010	Chart Rotation Delay	
Make of Meter Barton	Serial No. 188140	Differential Range 50	Static Range 50	Temp. Range 150	
Tester Joe Whitaker			Witness		
FOUND		LEFT		ORIFICE INST. • X •	
U-Tube	Diff.	U-Tube	Diff.	ORIFICE REM. • X •	
0	0	SAME		Ranarex ☒ Spec. Grav. .760	
20	20			Differential Reading Avg. 4.4 Static Reading Avg. 5.9	
30	30			Temp. Lock In 98 Atmos. Temp. 98	
50	50				
				Gas Temperature •	
				Cu. Ft. Gas Run •	
				Cu. Ft. Gas at 14.65 at 60° •	
				C.C. Recovered, Gross	
FOUND		LEFT		Temp. Gross Recovery	
D. W.	Static	D. W.	Static	Gals. Per M Gross •	
0	13.2	SAME		C.C. Recovered Net 60°	
5	18.2			Net G.P.M. at 60° •	
				H ₂ S = H ₂ O =	
				Charcoal ☐ U.P.T. No Gas ☐ Compression ☐	
AIR CONSTANT		FPB	FG	HOURLY COEFF	MC
				MCH COEFF	
Temp. Recorder Tested Yes ☒ No ☐		Found 103 Gauged 99 Left		OK SET ☒ ARC	OK SET ☐ LAG
				Orifice Plate Good ☒ Damaged ☐	

Remarks:

JUN 16 1999